

Test Report issued under the responsibility of:

Intertek

TEST REPORT IEC 62109-2 Safety of Power Converter for use in Photovoltaic Power Systems Part 2: Particular requirements for inverters

Report Number:	210623182GZU-002			
Date of issue:	27 Jul 2021			
Total number of pages	30 pages			
Name of Testing Laboratory	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch			
preparing the Report:	Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China			
Applicant's name:	INVT Solar Technology (Shenzhen) Co., Ltd.			
Address:	6 th Floor , Block A, INVT Guangming Technology Building, Kejie Fourth Road, Shutianpu Community, Matian Guangming District, 518000 Shenzhen, PEOPLE'S REPUBLIC OF CHINA			
Test specification:				
Standard:	IEC/EN 62109-2:2011			
Test procedure:	Type approval			
Non-standard test method:	N/A			
Test Report Form No:	IEC62109_2B			
Test Report Form(s) Originator:	LCIE - Laboratoire Central des Industries Electriques			
Master TRF:	Dated 2016-11			
Copyright © 2016 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.				
	part for non-commercial purposes as long as the IECEE is acknowledged as E takes no responsibility for and will not assume liability for damages resulting material due to its placement and context.			

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.



Total Quality. Assured.	Page 2 of 30	Report No. 210623182GZU-00			
Test item description	Grid-tied Solar inverter				
Trade Mark	invt				
Manufacturer	. Same as applicant				
Model/Type reference	iMars XG100KTR, iMars XG100KTR-F, iMars XG110KTR, iMars XG110KTF F, iMars XG136KTR-L, iMars XG136KTR-LF, iMars XG136KTR-X, iMars XG136KTR-XF				
Ratings	Model	iMars XG100KTR	iMars XG100KTR-F		
	Max.PV voltage	1100)Vdc		
	MPPT voltage range	180V – ⁻	1000Vdc		
	Max.input current	26A*9	30A*9		
	PV lsc	40/	۹*9		
	Nominal output voltage	3/N/PE, 23	30/400Vac		
	Nominal output Frequency	50/6	60Hz		
	Max.output current	158.8A			
	Rated output power	100KW			
	Max.apparent power	110KVA			
	Power factor range	0.8Leading – 0.8 lagging			
	Safety level	Class I			
	Ingress Protection	IP 66			
	Operation Ambient Temperature	- 30 ℃ - +60℃			
	Software version	V1.1			
	Model	iMars XG110KTR	iMars XG110KTR-F		
	Max.PV voltage	1100	0Vdc		
	MPPT voltage range	180V – 1	1000Vdc		
	Max.input current	26A*10	30A*10		
	PV lsc	404	*10		
	Nominal output voltage	3/N/PE, 23	30/400Vac		
	Nominal output Frequency	50/6	60Hz		
	Max.output current	174	I.6A		
	Rated output power	110	кw		
	Max.apparent power	121	KVA		
	Power factor range	0.8Leading -	- 0.8 lagging		



Page 3 of 30	Report No. 210623182GZU-00		
Safety level	Class I		
Ingress Protection	IP 66		
Operation Ambient Temperature	- 30 ℃ -	- +60 ℃	
Software version	V'	1.1	
Model	iMars XG136KTR-L	iMars XG136KTR-L	
Max.PV voltage	1100	0Vdc	
MPPT voltage range	180V – 1	1000Vdc	
Max.input current	26A*12	30A*12	
PV lsc	40A	×*12	
Nominal output voltage	3/N/PE, 2	77/480Vac	
Nominal output Frequency	50/6	60Hz	
Max.output current	174	1.6A	
Rated output power	136KW		
Max.apparent power	150KVA		
Power factor range	0.8Leading – 0.8 lagging		
Safety level	Class I		
Ingress Protection	IP 66		
Operation Ambient Temperature	-30 ℃ - +60 ℃		
Software version	V	1.1	
Model	iMars XG136KTR-X	iMars XG136KTR-X	
Max.PV voltage	1100	0Vdc	
MPPT voltage range	180V – 1	1000Vdc	
Max.input current	26A*12	30A*12	
PV lsc	404	x*12	
Nominal output voltage	3/N/PE, 3	11/540Vac	
Nominal output Frequency	50/60Hz		
Max.output current	160.4A		
Rated output power	136	бКW	
Max.apparent power	150	KVA	
Power factor range	0.8Leading	– 0.8 lagging	
Safety level	Cla	iss l	



iotal quality. Assured.	Page 4 of 30	Report No. 210623182GZU-002	
	Ingress Protection	IP 66	
	Operation Ambient Temperature	- 30 ℃ - +60℃	
	Software version	V1.1	



Total Quality. Assured.

 \bowtie

Page 4 of 30 Report No. 210623182GZU-002 Responsible Testing Laboratory (as applicable), testing procedure and testing location(s): **Testing Laboratory:** Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Testing location/ address: Room 02, & 101/E201/E301/E401/E501/E601/E701/E801 of Room 01 1-8/F., No. 7-2. Caipin Road, Science City, GETDD, Guangzhou, Guangdong, China Tested by (name, function, signature) : Gaison Li Gaison Li Jason Tu Engineer Jason Fu Approved by (name, function, signature)..: Supervisor Testing procedure: CTF Stage 1: N/A Testing location/ address: N/A Tested by (name, function, signature): N/A Approved by (name, function, signature)..: N/A **Testing procedure: CTF Stage 2:** N/A Testing location/ address: N/A N/A

Tested by (name + signature): Witnessed by (name, function, signature). : N/A Approved by (name, function, signature) .. : N/A Testing procedure: CTF Stage 3: N/A **Testing procedure: CTF Stage 4:** N/A Testing location/ address: N/A Tested by (name, function, signature) : N/A Witnessed by (name, function, signature). : N/A Approved by (name, function, signature)..: N/A Supervised by (name, function, signature) : N/A



Page 5 of 30

Report No. 210623182GZU-002

List of Attachments (including a total number of pages in each attachment):					
N/A					
Summary of testing:					
Summary of testing.	r				
Tests performed (name of test and test	Testing location:				
clause):	Intertek Testing Services Shenzhen Ltd.				
All applicable tests	Guangzhou Branch				
	Room 02, &				
	101/E201/E301/E401/E501/E601/E701/E801 of				
	Room 01 1-8/F., No. 7-2. Caipin Road, Science				
	City, GETDD, Guangzhou, Guangdong, China				
Summary of compliance with National Difference	as (List of countries addressed):				
	es (List of countries addressed).				
N/A					
☐ The product fulfils the requirements of IEC/EI	N 62100-2-2011				
	N 02109-2.2011				



Page 6 of 30

Copy of marking plate:

The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBs that own these marks.

invt	Grid-tied Solar Inverter	invt	Grid-tied Solar Inverter	invt	Grid-tied Solar Inverter	invt	Grid-tied Solar Inverter
iMars XG13	36KTR-L	iMars XG13	6KTR-LF	iMars XG13	B6KTR-X	iMars XG13	6KTR-XF
DC Input		DC Input		DC Input		DC Input	
Vmax. PV	1100V	Vmax. PV	1100V	Vmax. PV	1100V	Vmax. PV	1100V
MPPT Range	180V-1000V	MPPT Range	180V-1000V	MPPT Range	180V-1000V	MPPT Range	180V-1000V
Max. Current	26AX12	Max. Current	30AX12	Max. Current	26AX12	Max. Current	30AX12
Isc PV	40AX12	Isc PV	40AX12	Isc PV	40AX12	Isc PV	40AX12
AC Output		AC Output		AC Output		AC Output	
Nominal Voltage	3/N/PE,277/480V	Nominal Voltage	3/N/PE,277/480V	Nominal Voltage	3/N/PE,311/540V	Nominal Voltage	3/N/PE,311/540V
Nominal Current	174.6A	Nominal Current	174.6A	Nominal Current	160.4A	Nominal Current	160.4A
Rated Power	136000W	Rated Power	136000W	Rated Power	136000W	Rated Power	136000W
Max. Apparent Power	150000VA	Max. Apparent Power	15000VA	Max. Apparent Power	150000VA	Max. Apparent Power	150000VA
Frequency	50Hz/60Hz	Frequency	50Hz/60Hz	Frequency	50Hz/60Hz	Frequency	50Hz/60Hz
Power factor range	0.80un ~ 0.80ov	Power factor range	0.80un ~ 0.80ov	Power factor range	0.80un ~ 0.80ov	Power factor range	0.80un ~ 0.80ov
Environment		Environment		Environment		Environment	
Temperature	- 30° C∼+60°C	Temperature	- 30° C∼+60°C	Temperature	- 30° C∼+60°C	Temperature	- 30° C∼+60°C
Protective Class	I	Protective Class	I	Protective Class	I	Protective Class	I
Inverter topology	Non-isolated	Inverter topology	Non-isolated	Inverter topology	Non-isolated	Inverter topology	Non-isolated
Ingress protection	IP66	Ingress protection	IP66	Ingress protection	IP66	Ingress protection	IP66
	€₹	10min	CE 🖄		€₹		CE 🖄
	Made in China		Made in China		Made in China		Made in China
INVT Solar Technology	(Shenzhen) Co., Ltd.	INVT Solar Technology	(Shenzhen) Co., Ltd.	INVT Solar Technology	(Shenzhen) Co. Ltd.	INVT Solar Technology (Shenzhen) Co. Ltd

Total Quality. Assured.

Page 7 of 30

Report No. 210623182GZU-002

invt	Grid-tied Solar Inverter	invt	Grid-tied Solar Inverter	invt	Grid-tied Solar Inverter	invt	Grid-tied Solar Inverter
iMars XG1	OOKTR	iMars XG10	OKTR-F	iMars XG1	10KTR	iMars XG11	.0KTR-F
DC Input		DC Input		DC Input		DC Input	
Vmax. PV	1100V	Vmax. PV	1100V	Vmax. PV	1100V	Vmax. PV	1100V
VIPPT Range	180V-1000V	MPPT Range	180V-1000V	MPPT Range	180V-1000V	MPPT Range	180V-1000V
Max. Current	26AX9	Max. Current	30AX9	Max. Current	26AX10	Max. Current	30AX10
isc PV	40AX9	Isc PV	40AX9	Isc PV	40AX10	Isc PV	40AX10
AC Output		AC Output		AC Output		AC Output	
Nominal Voltage	3/N/PE,230/400V	Nominal Voltage	3/N/PE,230/400V	Nominal Voltage	3/N/PE,230/400V	Nominal Voltage	3/N/PE,230/400V
Nominal Current	158.8A	Nominal Current	158.8A	Nominal Current	174.6A	Nominal Current	174.6A
Rated Power	100000W	Rated Power	100000W	Rated Power	110000W	Rated Power	110000W
Vax. Apparent Power	110000VA	Max. Apparent Power	110000VA	Max. Apparent Power	121000VA	Max. Apparent Power	121000VA
Frequency	50Hz/60Hz	Frequency	50Hz/60Hz	Frequency	50Hz/60Hz	Frequency	50Hz/60Hz
Power factor range	0.80un ~ 0.80ov	Power factor range	0.80un ~ 0.80ov	Power factor range	0.80un ~ 0.80ov	Power factor range	0.80un ~ 0.80ov
Environment		Environment		Environment		Environment	
Temperature	-30°C ~ +60°C	Temperature	- 30° C ~ +60° C	Temperature	-30°C ~ +60°C	Temperature	- 30° C~+60°C
Protective Class	I	Protective Class	I	Protective Class	I	Protective Class	I
Inverter topology	Non-isolated	Inverter topology	Non-isolated	Inverter topology	Non-isolated	Inverter topology	Non-isolated
Ingress protection	IP66	Ingress protection	IP66	Ingress protection	IP66	Ingress protection	IP66
	€ ₹		€ ₹		€₹	10min (€₹
	Made in China		Made in China		Made in China		Made in China
INVT Solar Technology ((Shamehan) Ca. I tal	INVT Solar Technology	(Shanzhan) Co. Ltd	INVT Solar Technology (Chaushau) Ca Liad	INVT Solar Technology (characterized

Note:

- 1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
- 2. Label is attached on the side surface of enclosure and visible after installation.
- 3. Other labels are identical to above, except the model name and ratings



\$7 A37-8	Page 8 of	30 Report No. 210623182GZU-002		
Test item particulars	:			
Equipment mobility	:	movable hand-held stationary fixed transportable for building- in		
Connection to the mains	:	□ pluggable equipment □ direct plug-in ⊠ permanent connection □ for building-in		
Enviromental category	:	☑ outdoor ☐ indoor ☐ indoor unconditional conditional		
Over voltage category Mains	:			
Over voltage category PV	:			
Mains supply tolerance (%)	:	-90 / +110 %		
Tested for power systems	:	TN systems		
IT testing, phase-phase voltage (V)	:			
Class of equipment	:	☐ Class I ☐ Class II ☐ Class III ☐ Not classified		
Mass of equipment (kg)	:	Approx. 126Kg		
Pollution degree	:	Outside PD3; Inside PD2		
IP protection class	:	IP 66		
	:			
Possible test case verdicts:				
- test case does not apply to the test object	;t: :	N/A		
- test object does meet the requirement	:	P (Pass)		
- test object does not meet the requiremer	nt:	F (Fail)		
Testing	:			
Date of receipt of test item	:	23 Jun 2021		
Date (s) of performance of tests	:	24 Jun 2021 – 26 Jul 2021		



iotai Quality. Assureo.	Page 9 of 30		Report No. 210623182GZU-002					
General remarks:								
"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report.								
Throughout this report a 🗌 comma	/ 🛛 point is us	sed as the decimal	separator.					
This report shall be used together wi	This report shall be used together with report No.210623182GZU-001							
Manufacturer's Declaration per sub-	clause 4.2.5 of I	ECEE 02:						
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided								
When differences exist; they shall be identified in the General product information section.								
Name and address of factory (ies) : Shenzhen INVT Electric Co., Ltd. (Baoan Factory)								
4 th to 1 st floors of Emerson Industrial Park, No. 3, Fengtang Avenue, Tangwei Community, Fuhai Street, Baoan District, Shenzhen, CHINA.								



Page 10 of 30

General product information:

The control system is divided into DC and AC control. AC-DSP and CPLD on the AC side mainly monitors the voltage, current, frequency and GFCI on the grid side, and participates in the inverter control.

The DC-DSP monitors the voltage, current, and ISO on the PV input side, and participates in the BOOS booster circuit and maximum power MPPT point tracking.


There is an internal communication circuit between the two DSP to coordinate with each other to complete the software function of the whole machine.

The ARM monitoring board does not participate in the control of the whole system. It communicates with the DC-SPS to collect the data of the whole system.

The relays (K3,K4,K5,K6) are designed on redundant structure where K4,K6 are controlled by DC-DSP and K5,K6 are controlled by AC-DSP.

The AC-DSP and DC-DSP are used together to control relay open or close, if the single fault on one controller, the other controller can be capable of opening the relay, so that still providing safety means.

The topology diagram as following:



All models are identical, except the output power derating in software and components as list in CDF. The detailed difference as following:

Madal	iMars	iMars	iMars XG136KTR-	iMars XG136KTR-
Model	XG100KTR/iMar	XG110KTR/iMars	L/iMars	X/iMars



Total Quality. Assured.

		Page 11 of 30	Report	No. 210623182GZU-002
	s XG100KTR-F	XG110KTR-F	XG136KTR-LF	XG136KTR-XF
PV input	9 strings MPPT Each MPPT: two string input	10 strings MPPT Each MPPT: two string input	•	gs MPPT vo string input
AC output voltage	230/400Vac		277/480Vac	311/540Vac
The product was The Software ve				
The Hardware ve	ersion: VA.1			

Other than special notes, typical model iMars XG136KTR-L used as representative for testing in this report.

Total Quality. Assured.

Page 12 of 30

Report No. 210623182GZU-002

Verdict

		IEC 62109-2	
Clause	Requirement + Test		Result - Remark

4	GENERAL TESTING REQUIREMENTS				
4.4.4	Single fault conditions to be applied				
4.4.4.15	Fault-tolerance of protection for grid-interactive inverters		Р		
4.4.4.15.1	Fault-tolerance of residual current monitoring according to 4.8.3.5: the residual current monitoring system operates properly	See appended table 4.4.4.15.1	Р		
	a) The inverter ceases to operate		Р		
	- Indicates a fault in accordance with §13.9		P		
	- Disconnect from the mains		P		
	 not re-connect after any sequence of removing and reconnecting PV power 		P		
	 not re-connect after any sequence of removing and reconnecting AC power 		Р		
	 not re-connect after any sequence of removing and reconnecting both PV and AC power 		Р		
	b) The inverter continues to operate		N/A		
	 the residual current monitoring system operates properly under single fault condition 		N/A		
	 Indicates a fault in accordance with §13.9 		N/A		
	c) The inverter continues to operate regardless of loss of residual current monitoring functionality		N/A		
	 not re-connect after any sequence of removing and reconnecting PV power 		N/A		
	 not re-connect after any sequence of removing and reconnecting AC power 		N/A		
	 not re-connect after any sequence of removing and reconnecting both PV and AC power 		N/A		
	 Indicates a fault in accordance with §13.9 		N/A		
4.4.4.15.2	Fault-tolerance of automatic disconnecting means	Two series relays in each line and can independent operation for each relay.	Р		
4.4.4.15.2	The means provided for automatic disconnection of a		Р		
.1	grid-interactive inverter from the mains shall:				
	 disconnect all grounded current-carrying conductors from the mains 	Disconnected all line conductors from the mains	Р		
	 disconnect all ungrounded current-carrying conductors from the mains 		Р		
	 be such that with a single fault applied to the disconnection means or to any other location in the inverter, at least basic insulation or simple separation is maintained between the PV array and the mains when the disconnecting means is intended to be in the open state. 	See appended table 4.4.4.15.2 Fault-tolerance of automatic disconnecting There are two relays in serial used as automatic disconnection means. Contact gap is basic insulation.	Р		
4.4.4.15.2 .2	Design of insulation or separation complies with requirements of 7.3.7 of Part 1: report here Part 1	The automatic disconnection means is automatically	Р		

Total Quality. Assured.

Page 13 of 30

Report No. 210623182GZU-002

	IEC 62109-2	1	
Clause	Requirement + Test	Result - Remark	Verdict
	comment and verdict.	checked before the inverter start operation	
4.4.4.15.2 .3	For non-isolated inverter, automatic checking of the isolation provided by a disconnect means after single fault.	See appended test table 4.4.4.15.2 Fault-tolerance of automatic disconnecting.	P
	If the check fail: - any still-functional disconnection means shall be left in the open position		Р
	- at least basic or simple separation shall be maintained between the PV input and the mains		Р
	- the inverter shall not start operation		Р
	- the inverter shall indicate a fault in accordance with 13.9	The screen shown error information.	Р
4.4.4.16	A stand-alone inverter with a transfer switch to transfer AC loads from the mains or other AC bypass source to the inverter output:	No such transfer switch	N/A
	- shall continue to operate normally		N/A
	- shall not present a risk of fire as the result of an out-of- phase transfer		N/A
	- shall not present a risk of shock as the result of an out- of-phase transfer		N/A
	- And having control preventing switching: components for malfunctioning		N/A
4.4.4.17	Cooling system failure – Blanketing test No hazards according to the criteria of sub-clause 4.4.3 of Part 1 shall result from blanketing the inverter This test is not required for inverters restricted to use only in closed electrical operating areas.	See appended test table Cooling system failure – Blanketing test.	P
	Test stop condition: time duration value or stabilized temperature		Р
4.7	ELECTRICAL RATINGS TESTS	-	Р
4.7.4	Stand-alone Inverter AC output voltage and frequency		N/A
4.7.4.1	General		N/A
4.7.4.2	Steady state output voltage at nominal DC input The steady-state AC output voltage shall not be less than 90 % or more than 110 % of the rated nominal voltage with the inverter supplied with its nominal value of DC input voltage.		N/A
4.7.4.3	Steady state output voltage across the DC input range The steady-state AC output voltage shall not be less than 85 % or more than 110 % of the rated nominal voltage with the inverter supplied with any value within the rated range of DC input voltage.		N/A
4.7.4.4	Load step response of the output voltage at nominal DC input The AC output voltage shall not be less than 85 % or more than 110 % of the rated nominal voltage for more than 1,5 s after application or removal of a resistive load.		N/A

Total Quality. Assured.

Page 14 of 30

Report No. 210623182GZU-002

	IEC 62109-2		Т
Clause	Requirement + Test	Result - Remark	Verdict
4.7.4.5	Steady state output frequency The steady-state AC output frequency shall not vary from the nominal value by more than +4 % or -6 %.		N/A
4.7.5	Stand-alone inverter output voltage waveform		N/A
4.7.5.1	General		N/A
4.7.5.2	The AC output voltage waveform of a sinusoidal		N/A
	output stand-alone inverter shall have a total harmonic distortion (THD) not exceeding of 10 % and no individual harmonic at a level exceeding 6 %.		
4.7.5.3	Non-sinusoidal output waveform requirements		N/A
4.7.5.3.1	General		N/A
4.7.5.3.2	The total harmonic distortion (THD) of the voltage waveform shall not exceed 40 %.		N/A
4.7.5.3.3	The slope of the rising and falling edges of the positive and negative half-cycles of the voltage waveform shall not exceed 10 V/µs measured between the points at which the waveform has a voltage of 10 % and 90 % of the peak voltage for that half-cycle.		N/A
4.7.5.3.4	The absolute value of the peak voltage of the positive and negative half-cycles of the waveform shall not exceed 1,414 times 110 % of the RMS value of the rated nominal AC output voltage.		N/A
4.7.5.4	Information requirements for non-sinusoidal waveforms The instructions provided with a stand-alone inverter not complying with 4.7.5.2 shall include the information in 5.3.2.6.		N/A
4.7.5.5	Output voltage waveform requirements for inverters for dedicated loads. For an inverter that is intended only for use with a known dedicated load, the following requirements may be used as an alternative to the waveform requirements in 4.7.5.2 to 4.7.5.3.		
	The combination of the inverter and dedicated load shall be evaluated to ensure that the output waveform does not cause any hazards in the load equipment and inverter, or cause the load equipment to fail to comply with the applicable product safety standards.		N/A
	The inverter shall be marked with symbols 9 and 15 of Table C.1 of Part 1.		N/A
	The installation instructions provided with the inverter shall include the information in 5.3.2.13.		N/A
4.8	ADDITIONAL TESTS FOR GRID-INTERACTIVE INVERTE	RS	Р
4.8.1	General requirements regarding inverter isolation and array grounding	Non-isolation inverter	N/A
	- Type of Array grounding supported:		N/A
	- Inverter isolation		N/A
4.8.2	Array insulation resistance detection for inverters for ungrounded and functionally grounded arrays	(See attached table)	P
		1	1
4.8.2.1	Array insulation resistance detection for inverters for ungrounded arrays		Р

Total Quality. Assured.

ſ

Page 15 of 30

Report No. 210623182GZU-002

	IEC 62109-2		
Clause	Requirement + Test	Result - Remark	Verdict
	resistance from PV input (array) to ground before starting operation		
	Or Inverter shall be provided with instruction in accordance with 5.3.2.11.	The inverter can measure DC insulation resistance from PV input array to ground before starting operation	N/A
	Measured DC insulation resistance:		Р
	Inverter measurement circuit shall be capable of detecting insulation resistance below the limit value R= Vmax/30mA under normal conditions		Р
	Inverter measurement circuit shall be capable of detecting insulation resistance below the limit value R= Vmax/30mA with ground fault in the PV array		Р
	Isolated inverters shall indicate a fault if the insulation resistance is less than the limit value		N/A
	Isolated inverter fault indication maintained until insulation resistance has recovered to a value higher than the limit value		N/A
	Non-isolated inverters, or inverters with isolation not comply limits in the minimum inverter isolation requirements in Table		Р
	- shall indicate a fault in accordance with 13.9		Р
	- shall not connect to the mains		Р
4.8.2.2	Array insulation resistance detection for inverters for functionally grounded arrays		N/A
	a-1)The value of the total resistance, including the intentional resistance for array functional grounding, the expected insulation resistance of the array to ground, and the resistance of any other networks connected to ground (for example measurement networks) must not be lower than R = (VMAX PV/30 mA) ohms.		N/A
	a-2) The installation instructions shall include the information required in 5.3.2.12.		N/A
	b-1) As an alternative to a), or if a resistor value lower than in a) is used, the inverter shall incorporate means to detect, during operation, if the total current through the resistor and any networks (for example measurement networks) in parallel with it, exceeds the residual current values and times in Table 31		N/A
	b-2) Inverter shall either disconnect the resistor or limit the current by other means		N/A
	b-3) If the inverter is a non-isolated inverter, or has isolation not complying with the leakage current limits in the minimum inverter isolation requirements in Table 30, it shall also disconnect from the mains.		N/A
	 c) The inverter shall have means to measure the DC insulation resistance from the PV input to ground before starting operation, in accordance with 4.8.2.1. 		N/A
4.8.3	Array residual current detection		Р
4.8.3.1	General		Р
4.8.3.2	30 mA touch current type test for isolated inverters		N/A

Total Quality. Assured.

Page 16 of 30

Report No. 210623182GZU-002

	IEC 62109-2		
Clause	Requirement + Test	Result - Remark	Verdict
4.8.3.3	Fire hazard residual current type test for isolated inverters		N/A
4.8.3.4	Protection by application of RCD's	Integrated RCM inside PCE	Р
	- The requirement for additional protection in 4.8.3.1 can be met by provision of an RCD with a residual current setting of 30 mA, located between the inverter and the mains		P
	 The selection of the RCD type to ensure compatibility with the inverter must be made according to rules for RCD selection in Part 1. 		Р
	- The RCD provided integral to the inverter, or		Р
	- The RCD provided by the installer if details of the rating, type, and location for the RCD are given in the installation instructions per 5.3.2.9.		N/A
4.8.3.5	Protection by residual current monitoring		Р
4.8.3.5.1	General		Р
	Where required by Table 30, the inverter shall provide residual current monitoring that functions whenever the inverter is connected to the mains with the automatic disconnection means closed.		Р
	The residual current monitoring means shall measure the total (both a.c. and d.c. components) RMS current.		Р
	As indicated in Table 30 for different inverter types, array types, and inverter isolation levels, detection may be required for excessive continuous residual current, excessive sudden changes in residual current, or both, according to the following limits:		Р
	 a) Continuous residual current: The inverter shall disconnect in accordance with 13.9 if the continuous residual current ex 		Р
	 maximum 300 mA for inverters with continuous ouput power rating ≤30kVA; 		Р
	 maximum 10 mA per kVA of rated continuous output power for inverters with continuous output power rating > 30 kVA. 		N/A
	The inverter may attempt to re-connect if the array insulation resistance meets the limit in 4.8.2.		Р
	b) Sudden changes in residual current: The inverter shall disconnect from the mains within the time specified in Table 31		P
	The inverter indicates a fault in accordance with 13.9, if a sudden increase in the RMS residual current is detected exceeding the value in the table.		Р
	The inverter may attempt to re-connect if the array insulation resistance meets the limit in 4.8.2.		Р
4.8.3.5.2	Test for detection of excessive continuous residual current: test repeated 5 times and time to disconnect shall not exceed 0,3 s.	See appended test table 4.8.3.5.2 Test for detection of excessive continuous residual current	Р
4.8.3.5.3	Test for detection of sudden changes in residual current repeated 5 times and each of the 5 results shall not exceed the time limit indicated in for each row		Р

Total Quality. Assured.

Page 17 of 30

Report No. 210623182GZU-002

IEC 62109-2

	IEC 62109-2		
Clause	Requirement + Test	Result - Remark	Verdict
	(30mA, 60mA and150mA) of Table 31.		
4.8.3.6	Systems located in closed electrical operating areas		N/A
	The protection against shock hazard is not required if the installation information provided with the inverter indicates the restriction for use in a closed electrical operating area, and		N/A
	Installation information indicates what forms of shock hazard protection are and are not provided integral to the inverter, in accordance with 5.3.2.7.		N/A
	The inverter shall be marked as in 5.2.2.6.		N/A
5	MARKING AND DOCUMENTATION		Р
- 5.1	Marking		P
5.1.4	Equipment ratings		P
	PV input ratings:	See markings	Р
	- Vmax PV (absolute maximum) (d.c. V)	<u>_</u>	Р
	- Isc PV (absolute maximum) (d.c. A)		Р
	a.c. output ratings:		Р
	- Voltage (nominal or range) (a.c. V)		Р
	- Current (maximum continuous) (a.c. A)		P
	- Frequency (nominal or range) (Hz)		P
	- Power (maximum continuous) (W or VA)		P
	- Power factor range		P
	a.c input ratings:		N/A
	- Voltage (nominal or range) (a.c. V)		N/A
	- Current (maximum continuous) (a.c. A)		N/A
	- Frequency (nominal or range) (Hz)		N/A
	d.c input (other than PV) ratings:		N/A
	- Voltage (nominal or range) (d.c. V)		N/A
	- Current (maximum continuous) (d.c. A)		N/A
	d.c. output ratings:		N/A
	- Voltage (nominal or range) (d.c. V)		N/A
	- Current (maximum continuous) (d.c. A)		N/A
	Protective class (I or II or III)	-	P
	Ingress protection (IP) rating per part 1		P
	An inverter that is adjustable for more than one nominal output voltage shall be marked to indicate the particular voltage for which it is set when shipped from the factory.		N/A
5.2	Warning markings	-	Р
5.2.2	Content for warning markings	Р	
5.2.2.6	Inverters for closed electrical operating areas		N/A
	Where required by 4.8.3.6, an inverter not provided with full protection against shock hazard on the PV array shall be marked with a warning that the inverter is only for use in a closed electrical operating area, and referring to the installation instructions.		N/A
5.3	Documentation		P
5.3.2	Information related to installation		Р

Total Quality. Assured.

Page 18 of 30

Report No. 210623182GZU-002

IEC 62109-2					
Clause	equirement + Test Result - Remark		Verdic		
5.3.2.1	Ratings. Subclause 5.3.2 of Part 1 requires the documentation to include ratings information for each input and output. For inverters this information shall be as in Table 33 below. Only those ratings that are applicable based on the type of inverter are required.				
	PV input quantities :		Р		
	- Vmax PV (absolute maximum) (d.c. V)		Р		
	- PV input operating voltage range (d.c. V)		Р		
	- Maximum operating PV input current (d.c. A)		Р		
	- Isc PV (absolute maximum) (d.c. A)		Р		
	- Isc PV (absolute maximum) (d.c. A)		Р		
	- Max. inverter backfeed current to the array (a.c. or d.c. A)		Р		
	a.c. output quantities:		Р		
	- Voltage (nominal or range) (a.c. V)		Р		
	- Current (maximum continuous) (a.c. A)		Р		
	- Current (inrush) (a.c. A, peak and duration)		Р		
	- Frequency (nominal or range) (Hz)		Р		
	- Power (maximum continuous) (W or VA)		P		
	- Power factor range		Р		
	 Maximum output fault current (a.c. A, peak and duration or RMS) 		Р		
	- Maximum output overcurrent protection (a.c. A)		Р		
	a.c. input quantities:		N/A		
	- Voltage (nominal or range) (a.c. V)		N/A		
	- Current (maximum continuous) (a.c. A)		N/A		
	- Current (inrush) (a.c. A, peak and duration)		N/A		
	- Frequency (nominal or range) (Hz)		N/A		
	d.c input (other than PV) quantities:		N/A		
	- Voltage (nominal or range) (d.c. V)		N/A		
	- Nominal battery voltage (d.c. V)		N/A		
	- Current (maximum continuous) (d.c. A)		N/A		
	d.c. output quantities:		N/A		
	- Voltage (nominal or range) (d.c. V)		N/A		
	- Nominal battery voltage (d.c. V)		N/A		
	- Current (maximum continuous) (d.c. A)		N/A		
	Protective class (I or II or III)		P		
	Ingress protection (IP) rating per part 1		P		
5.3.2.2	Grid-interactive inverter setpoints		N/A		
	For a grid-interactive unit with field adjustable trip points, trip times, or reconnect times, the presence of such controls, the means for adjustment, the factory default	No adjustable setting available. Only the factory default values, however the	N/A		
	values, and the limits of the ranges of adjustability shall be provided in the documentation for the PCE or in other format such as on a website.	adjustment shall be performe d by distribution network operator.			
	Provided solution: The setting of field adjustable setpoints shall be accessible from the PCE		N/A		
5.3.2.3	Transformers and isolation		N/A		

Total Quality. Assured.

Page 19 of 30

Report No. 210623182GZU-002

	IEC 62109-2	1
Clause	Requirement + Test Result - Remark	Verdict
	whether an internal isolation transformer is provided, and if so, what level of insulation (functional, basic, reinforced, or double) is provided by that transformer. The instructions shall also indicate what the resulting installation requirements are regarding such things as earthing or not earthing the array, providing external residual current detection devices, etc.	N/A
	An inverter shall be provided with information to the installer regarding:	N/A
	- providing of internal isolation transformer	N/A
	 the level of insulation (functional, basic, reinforced, or double) 	N/A
	The instructions shall also indicate what the resulting installation requirements are regarding:	N/A
	- earthing or not earthing the array	N/A
	- providing external residual current detection devices	N/A
	- requiring an external isolation transformer,	N/A
5.3.2.4	Transformers required but not provided	N/A
	An inverter that requires an external isolation transformer not provided with the unit, shall be provided with instructions that specify, and for the external isolation transformer with which it is intended to be used:	N/A
	- the configuration type	N/A
	- electrical ratings	N/A
	- environmental ratings	N/A
5.3.2.5	PV modules for non-isolated inverters	Р
	Non-isolated inverters shall be provided with installation instructions that require PV modules that have an IEC 61730 Class A rating	Р
	If the maximum AC mains operating voltage is higher than the PV array maximum system voltage then the instructions shall require PV modules that have a maximum system voltage rating based upon the AC mains voltage.	N/A
5.3.2.6	Non-sinusoidal output waveform information	N/A
	The instruction manual for a stand-alone inverter not complying with 4.7.5.2 shall include a warning that:	N/A
	- the waveform is not sinusoidal,	N/A
	- some loads may experience increased heating,	N/A
	 the user should consult the manufacturers of the intended load equipment before operating that load with the inverter 	N/A
	The inverter manufacturer shall provide information regarding:	N/A
	 what types of loads may experience increased heating 	N/A
	recommendations for maximum operating times with such loads	N/A
	The inverter manufacturer shall specify for the waveforms as determined by the testing in 4.7.5.3.2 through 4.7.5.3.4.:	N/A
	- THD	N/A
	- slope	N/A
	- peak voltage	N/A

Total Quality. Assured.

Page 20 of 30

Report No. 210623182GZU-002

	IEC 62109-2		
Clause	Requirement + Test	Result - Remark	Verdict
5.3.2.7	Systems located in closed electrical operating areas		N/A
	Where required by 4.8.3.6, an inverter not provided with full hazard on the PV array shall be provided with installation in		N/A
	 requiring that the inverter and the array must be installed in closed electrical operating areas 		N/A
	 indicating which forms of shock hazard protection are and are not provided integral to the inverter (for example the RCD, isolation transformer complying with the 30 mA touch current limit, or residual current monitoring for sudden changes) 		N/A
5.3.2.8	Stand-alone inverter output circuit bonding		N/A
	Where required by 7.3.10, the documentation for an inverte	r shall include the following:	N/A
	 if output circuit bonding is required but is not provided integral to the inverter, the required means shall be described in the installation instructions, including which conductor is to be bonded and the required current carrying capability or cross-section of the bonding means; 		N/A
	 if the output circuit is intended to be floating, the documentation for the inverter shall indicate that the output is floating. 		N/A
5.3.2.9	Protection by application of RCD's	Integrated RCM used inside	N/A
	Where the requirement for additional protection in 4.8.3.1 is met by requiring an RCD that is not provided integral to the inverter, as allowed by 4.8.3.4, the installation instructions shall state the need for the RCD,.		N/A
	and shall specify its rating, type, and required circuit location		N/A
5.3.2.10	Remote indication of faults		Р
	The installation instructions shall include an explanation of how to properly make connections to (where applicable), and use, the electrical or electronic fault indication required by 13.9.	The instructions are specified insection "Warning List "of th e product manual.	Р
5.3.2.11	External array insulation resistance measurement and response	Integrated resistance measurement inside	N/A
	The installation instructions for an inverter for use with ungra incorporate all the aspects of the insulation resistance meas requirements in 4.8.2.1, must include:		N/A
	- for isolated inverters: an explanation of what aspects of array insulation resistance measurement and response are not provided, and		N/A
	 an instruction to consult local regulations to determine if any additional functions are required or not; 		N/A
	 for non-isolated inverters: an explanation of what external equipment must be provided in the system, and 		N/A
	- what the setpoints and response implemented by that equipment must be, and:		N/A
	 how that equipment is to be interfaced with the rest of the system. 		N/A

Total Quality. Assured.

Page 21 of 30

Report No. 210623182GZU-002

	IEC 62109-2					
Clause	Requirement + Test	Result - Remark	Verdict			
5.3.2.12	Array functional grounding information		N/A			
	Where approach a) of 4.8.2.2 is used, the installation instructions for the inverter shall include all of the following:					
	 a) the value of the total resistance between the PV circuit and ground integral to the inverter 					
	 b) the minimum array insulation resistance to ground that system designer or installer must meet when selecting the PV panel and system design, based on the minimum value that the design of the PV functional grounding in the inverter was based on; 		N/A			
	 c) the minimum value of the total resistance R = VMAX PV/30 mA that the system must meet, with an explanation of how to calculate the total; 		N/A			
	d) a warning that there is a risk of shock hazard if the total minimum resistance requirement is not met.		N/A			
5.3.2.13	Stand-alone inverters for dedicated loads		N/A			
	Where the approach of 4.7.5.5 is used, the installation instructions for the inverter shall include a warning that the inverter is only to be used with the dedicated load for which it was evaluated, and		N/A			
	shall specify the dedicated load.		N/A			
5.3.2.14	Identification of firmware version(s)					
	An inverter utilizing firmware for any protective functions shall provide means to identify the firmware version.		Р			
	This can be a marking, but the information can also be provided by a display panel, communications port or any other type of user interface	The firmware version is displayed on LCD display panel and disclosed by communication interface.	P			
7	PROTECTION AGAINST ELECTRIC SHOCK AND ENERG	GY HAZARDS	Р			
7.3	Protection against electric shock		P			
7.3.10	Additional requirements for stand-alone inverters		N/A			
	One circuit conductor bonded to earth to create a grounded conductor and an earthed system.		N/A			
	The means used to bond the grounded conductor to protective earth provided within the inverter or		N/A			
	as part of the installation		N/A			
	If not provided integral to the inverter, the required means shall be described in the installation instructions as per 5.3.2.8.		N/A			
	The means used to bond the grounded conductor to protective earth shall comply with the requirements for protective bonding in Part 1,		N/A			
	If the bond can only ever carry fault currents in stand- alone mode, the maximum current for the bond is determined by the inverter maximum output fault current.		N/A			

Total Quality. Assured.

Page 22 of 30

Report No. 210623182GZU-002

	IEC 62109-2				
Clause	Requirement + Test	Result - Remark	Verdict		
	Output circuit bonding arrangements shall ensure that in any mode of operation, the system only has the grounded circuit conductor bonded to earth in one place at a time		N/A		
	Switching arrangements may be used, in which case the switching device used is to be subjected to the bond impedance test along with the rest of the bonding path		N/A		
	Inverters intended to have a circuit conductor bonded to earth shall not impose any normal current on the bond except for leakage current.		N/A		
	Outputs that are intentionally floating with no circuit conductor bonded to ground, must not have any voltages with respect to ground that are a shock hazard in accordance with Clause 7 of Parts 1 and 2.		N/A		
	The documentation for the inverter shall indicate that the output is floating as per 5.3.2.8.		N/A		
7.3.11	Functionally grounded arrays		N/A		
	All PV conductors in a functionally grounded array shall be treated as being live parts with respect to protection against electric shock.		N/A		
9	PROTECTION AGAINST FIRE HAZARDS		P		
9.3	Short-circuit and overcurrent protection		P P		
9.3.4	Inverter backfeed current onto the array				
	The backfeed current testing and documentation requirements in Part 1 apply, including but not limited to the following.				
	Inverter backfeed current onto the PV array maximum value		Р		
	This inverter backfeed current value shall be provided in the installation instructions regardless of the value of the current, in accordance with Table 33.	No backfeed current that can flow out of the inverter PV input terminals.	P		
13	PHYSICAL REQUIREMENTS		Р		
13.9	Fault indication		P		
	Where this Part 2 requires the inverter to indicate a fault, both of the following shall be provided:				
	a) a visible or audible indication, integral to the inverter, and detectable from outside the inverter, and		Р		
	b) an electrical or electronic indication that can be remotely accessed and used.		Р		
	The installation instructions shall include information regarding how to properly make connections (where applicable) and use the electrical or electronic means in b) above, in accordance with 5.3.2.10.		Р		

Total Quality. Assured.

Page 23 of 30

Report No. 210623182GZU-002

IEC 62109-2

Clause Requirement + Test

Result - Remark

Verdict

4.4.4	TABLE: Single fault condition to be applied						Р
	Ambient temperatur	e (°C)		:	25		
	Power source for El model/type, output r		,	:			
4.4.4.15.1	Fault-tolerance of re	sidual cu	rrent mon	itoring			
Componen t No.	Fault	Supply voltage (V)	Test time	Fuse #	Fuse current (A)	Observation	
U1 (Pin12- 13) (AC Sampling board)	S-C	850	3min			The PCE can't start. Can rese damage. No hazard. Error me 02	
SN4 (Pin2- 4) (AC Sampling board)	S-C	850	3min			The PCE can't start. Can rese damage. No hazard. Error me 01	
C16 (AC Sampling board)	S-C	850	3min			The PCE can't start. Can rese damage. No hazard. Error me 01	
C15 (AC Sampling board)	S-C	850	3min			The PCE can't start. Can rese damage. No hazard. Error me 01	
Check that t	he residual current n	nonitoring	operates	properly	•		
Supplement	ary information:						

4.4.4	TABLE: Single fa	ault condit	ion to be	applied		Р		
	Ambient temperature (°C)				25			
		Power source for EUT: Manufacturer,						
4.4.4.15.2	Fault-tolerance of automatic disconnecting means							
Component No.	Fault	Supply voltage (V)	Test time	Fuse #	Fuse current (A)	Observation		
Relay K1 (L1 phase)	s-c before start up	850	3min			The PEC can't connect to grid. Can resettable. No damage. No hazard. Error message:11-02		
Relay K3 (L2 phase)	s-c before start up	850	3min			The PEC can't connect to grid resettable. No damage. No ha Error message:11-02		

Total Quality. Assured.

Page 24 of 30

Report No. 210623182GZU-002

IEC 62109-2

				IEC 62109-	·2			
Clause R	equirement + Test					Result - Remark	Verdict	
Relay K5 (L3 phase)	s-c before start up	850	3min			The PEC can't connect to grid resettable. No damage. No ha Error message:11-02		
G-D of Q2 (AC Sampling board)	s-c before start up	850	3min			The PCE can't start. Can resettable. N damage. No hazard. Error message:1 02		
G-S of Q2 (AC Sampling board)	s-c before start up	850	3min			The PCE can't start. Can resettable. No damage. No hazard. Error message:11-02		
D-S of Q2 (AC Sampling board)	s-c before start up	850	3min			The PCE can't start. Can resettable. No damage. No hazard. Error message:11		
R333 (AC Sampling board)	o-c before start up	850	3min			Operating as normal. No damage. No hazard.		
TR1 (ARM board)	s-c before start up	850	3min			The PCE can't start. Can resettable. No damage. No hazard.		
PC3 (ARM board)	s-c before start up	850	3min			The PCE can't start. Can resettable. No damage. No hazard.		
SN2 (PV board)	s-c before start up	850	3min			The PCE can't start. Can reset damage. No hazard. Error me 01		
TR1 (PIN2-3) (driver board)	s-c before start up	850	3min			The PCE can't start. Can resettable. N damage. No hazard.		
	e relays fulfil the ba PV circuit working		ition or sir	nple separa	ation	There are two relays in serial us automatic disconnection means		
Each active pl	nase can be switch	ed. (L an	d N)					
Supplementar	information:							

4.4.4.17	Cooling system fainlure – Blanketing tes	t			Р
	Test voltage (Vdc):				
	Test current (Idc)		269.7		
	Test voltage (Vac):	227.0	227.0	227.0	
	Test current (lac)	168.0	165.9	165.4	
	t _{amb1} (°C):		27.34		
	t _{amb2} (°C):		29.41		
maximum	temperature T of part/at::		T (°C)		T _{max} (°C)
Ambient te	emp.		45.00		

Total Quality. Assured.

Page 25 of 30

Report No. 210623182GZU-002

IEC 62109-2					
Clause	Requirement + Test	Result - Remark	Verdict		
Enclosure	е (Тор)	50.99	90		
Enclosure (Side)		50.27	90		
Enclosure (front)		57.66	90		
Enclosure	e (Bottom)	56.31	90		
Mounting surface		57.65	90		
Suppleme	entary information:		·		

4.7.4	TABLE: Steady state	Inverter AC output voltage and frequen	су	N/A
	Nominal DC input (V)			
	Nominal output AC vo	oltage (V) :		
AC output U (V)	Frequency (Hz) Condition/status		Comments	
Supplement	tary information:			

Total Quality. Assured.

Page 26 of 30

Report No. 210623182GZU-002

IEC 62109-2

				IEC 62109-2				
Clause	Re	quirem	ent + Test		F	Result - Rema	rk	Verdict
4.8.2			E: Array insulation res	istance detection for ir	nverters	for ungrounde	ed and	Р
4.8.2.1		Array	insulation resistance	detection for inverters	for ungro	ounded arrays	6	Р
			DC Voltage for inverter begin operation (V)	Resistance between ground and PV input terminal (Ω)	res	ed Insulation sistance _{IAX PV} / 30mA) (Ω)	F	Result
				DC+				
180V			250V	45.0kohm	36.67kc	bhm	The PV inverter cannot start-up. Error message "07-01"	
180V			250V	45.0kohm	36.67kc	bhm	The PV inverter cannot start-up. Error message "07-01"	
				DC-			L	
180V			250V	45.0kohm	36.67kc	bhm	_	erter cannot ror message:
180V 250V		250V	45.0kohm	36.67kc	bhm	The PV inverter cannot start-up. Error message: "07-01"		
Note:			1	1	L		l	
				accordance with 13.9 tance has recovered to				

For non-isolated inverters, or inverters with isolation not complying with the leakage current limits in the minimum inverter isolation requirements in Table 30, shall indicate a fault in accordance with 13.9, and shall not connect to the mains; the inverter may continue to make the measurement, may stop indicating a fault and may connect to the mains if the array insulation resistance has recovered to a value higher than the limit above.

It is not required to test all PV input terminals if analysis of the design indicates that one or more terminals can be expected to have the same result, for example where multiple PV string inputs are in parallel.

Supplementary information:

4.8.3.2	TABLE: 30mA touch current type test for isolated inverters					
C	ondition	Current (mA)	Limit (30mA)			
DC+ to PE						
D	C- to PE					

Total Quality. Assured.

Page 27 of 30

Report No. 210623182GZU-002

IEC 62109-2

Supplementary information:

The touch current measurement circuit of IEC 60990, Figure 4 is connected from each terminal of the array to ground, one at a time.

4.8.3.3 TABLE: Fire hazard r	TABLE: Fire hazard residual current type test for isolated inverters				
Condition	Current (mA)	Limit (300mA or 10mA per kVA)			
DC+ to PE					
DC- to PE					
Supplementary information:					

Total Quality. Assured.

Page 28 of 30

Report No. 210623182GZU-002

IEC 62109-2

		IEC		
Clause	Requirement -	+ Test	Result - Remark	Verdict
4.8.3.5	TABLE: Prot	ection by residual current mon	itoring	Р
Test conditions: Input voltage (V _{DC}): 85 Frequency (Hz):50		Output power (kVA) : 136 Input voltage (V _{DC}): 850 Frequency (Hz):50 Output AC Voltage (V _{AC})		/
4.8.3.5.2	Test for detection of excessive continu		s residual current	Р
Fault Current (mA)			Disconnection time (ms	5)
Limit Measured 300mA for output power ≤ 30 kVA Fault Current 10mA per kVA for output power >		Limit for output power ≤ 30 kVA	Measured Disconnection time	Limit
		+ P	V to N:	
289	1360		195	300
293	1360		201	300
287		1360	198	300
291		1360	197	300
285		1360	203	300
		-	PV to N:	
287		1360	195	300
286		1360	201	300
290		1360	198	300
281		1360	197	300
283		1360	203	300
Note: – maximul – maximul kVA. This test s The test is design ind	m 10mA per kVA hall be repeated repeated for ea	erters with continuous output A of rated continuous output p 5 times, and for all 5 tests the och PV input terminal. It is not or more terminals can be expe		it power rating > 3 3s. analysis of the
	ntary information			
Suppleme	mary information	1.		

TABLE: Test for detection of sudden changes in residual current		Р		
+PV to N				
Limit (mA)				
Disconnection time (ms)	LIN	nit (ms)		
129.0		300		
142.0		300		
141.0		300		
150.0		300		
140.0		300		
	+PV to N U _N Disconnection time (ms) 129.0 142.0 141.0 150.0	+PV to N UN Disconnection time (ms) 129.0 142.0 141.0 150.0 Lin 150.0 10 10 10 10 10 10 10		

Total Quality. Assured.

Page 29 of 30 Report No. 210623182GZU-002 IEC 62109-2 Clause Requirement + Test Result - Remark Verdict 60 99.2 150 150 94.8 60 60 102.8 150 150 60 92.8 150 60 94.4 150 24.4 40 40 150 16.4 24.8 40 150 150 38.4 40 40 150 30.4 -PV to N UN Limit (mA) Limit (ms) Disconnection time (ms) 30 134.4 300 300 30 133.6 30 149.6 300 300 30 140.4 300 30 132.8 60 113.2 150 150 60 107.6 150 60 113.6 60 100.8 150 60 102.4 150 150 31.6 40 29.6 40 150 40 150 32.0 40 150 19.2 150 27.6 40 Note: The capacitive current is raised until disconnection. Test condition: I_c + 30/60/150mA <= I_{cmax} . R_1 is set that 30/60/150mA Flow and switch S is closed. Supplementary information:

(End of report)